

产品认证证书

II型自愿认证

证书编号: CQC2018010308106863

发证日期: 2023年12月20日
有效期至: 2033年06月14日

委托人名称 Mersen France SB S.A.S.
及注册地址 15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

制造商名称 Mersen France SB S.A.S.
及注册地址 15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

生产企业名称 Mersen France SB S.A.S.
及生产地址 15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

产品名称和系列、规格、型号 半导体设备保护用熔断体
D □ SG120V□□; Un: DC1200V;In: Fuse size72:160A,200A,250A,315A,350A,400A,420A;Fuse size 272:500A,630A,800A,840A;额定分断能力: 100kA;分断范围和使用类别: aR; 型号解释见附件

产品标准和技术要求 GB/T 13539.4-2016

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年08月06日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

郑泉

谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0266429

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2018010308106863

Valid from: Dec.20,2023

Valid until: Jun.14,2033

NAME AND REGISTERED ADDRESS OF THE APPLICANT Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND LOCATION OF THE FACTORY Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

PRODUCT NAME, MODEL AND SPECIFICATION SEMICONDUCTOR PROTECTION FUSES
D □ SG120V□□; Un: DC1200V;In: Fuse size72:160A,200A,250A,315A,350A,400A,420A;Fuse size 272:500A,630A,800A,840A;Rated breaking capacity: 100kA; Breaking Range and Utilization Category:aR; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 13539.4-2016

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Aug.06,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

郑士泉

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86 10 83886666

C(2) 0266429

产品认证证书

II型自愿认证

附 录

证书编号: CQC2018010308106863

第 1 页 共 1 页

纸 号: 266429

型号的解释:

D □ SG □ □ QF example D72SG120V315QF
1 2 3 4 5 6

1 : D , means square body fuse for semiconductor protection

2 : □ , Fuse size 72 or 272

3 : SG , breaking range and utilization category aR

4 : □ , rated voltage 1200 divided by ten

5 : □ , rated current

6 : QF , suffix for end connection,

may be followed by "B" for salt spray atmosphere finition or by "M" with monitoring

注: 此附录与证书同时使用时有效。



中国质量认证中心

