



REV	DATE	BY	DESCRIPTION
00	5/93		RELEASED



P/N	CONN TYPE	TORQUE (IN-LBS)
2611	STUD	480

**CONTROLLED COPY**

ISSUED TO NEWBURY PORT  
DATE MAY 10 1993



P/N 2611

**GOULD** ELECTRIC  
P.O. BOX 728  
CLEVELAND, OHIO 44101-0728

DESIGNED BY: KDS DATE: 5/93  
DRAWN BY: GH0 DATE: 5/93

SCALE: NONE  
REFDOC: \*\*

IDENTIFICATION NO. 1 REVISION 00

DESCRIPTION: FUSE BLOCK, 250V-600A

- 2. 250V-600A 1 POLE W/STUD CONN.
  - 1. MATERIAL COMPOSITION AND RATING:  
BASE - PHENOLIC  
CONNECTOR - STEEL STUD W/ TIN PLATED COPPER ALLOY CLIP
- NOTES: UNLESS OTHERWISE SPECIFIED

TELERANCE TO BE APPLIED UNLESS OTHERWISE SPECIFIED. APPROVALS: JAZZ, OBI, JAZZ, OBI, UNLESS OTHERWISE SPECIFIED. UNLESS OTHERWISE SPECIFIED. UNLESS OTHERWISE SPECIFIED. ALL SURFACES TO BE 100% UNLESS OTHERWISE SPECIFIED.

THIS DRAWING IS THE PROPERTY OF GOULD ELECTRIC. IT IS TO BE KEPT CONFIDENTIAL AND NOT REPRODUCED OR COPIED UNLESS AUTHORIZED.