


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switch-disconnector-fuse
Name and address of the applicant	MERSEN FRANCE SB SAS 15 rue Jacques de Vaucanson, 69720 ST BONNET DE MURE - France
Name and address of the manufacturer	MERSEN FRANCE SB SAS 15 rue Jacques de Vaucanson, 69720 ST BONNET DE MURE - France
Name and address of the factory	MERSEN FRANCE SB SAS 15 rue Jacques de Vaucanson, 69720 ST BONNET DE MURE - France
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark (if any)	Mersen
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	D0 LINO CUR series References : See Annex
Additional information (if necessary may also be reported on page 2)	<input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2007(ed.5) +A1:2010 +A2:2014 IEC 60947-3:2008 (ed.3) +A1:2012 +A2:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	96147-591415/A Cr 2010-07-19, 146752-698936

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 27/02/2017

Signature: **Jean-François BRUEL**
Certification Officer


ANNEX
References, ratings and main characteristics
Series D0 LINO CUR

Models	Ie(A)	Nb of poles	Ue (V)
05861.020000	20	1	230
05861.025000	25	1	230
05861.035000	35	1	230
05861.050000	50	1	230
05861.063000	63	1	230
05862.020000	20	2	400
05862.025000	25	2	400
05862.035000	35	2	400
05862.050000	50	2	400
05862.063000	63	2	400
05863.020000	20	3	400
05863.025000	25	3	400
05863.035000	35	3	400
05863.050000	50	3	400
05863.063000	63	3	400
05861.063100	63	1+N	230
05863.063100	63	3+N	400

- method of operation	Manually operated
- suitability for isolation	suitable
- degree of protection	IP20
- kind of current	AC
- number of positions of the main contacts	2
Rated and limiting values, main circuit	
- rated operational voltage Ue (V)	230/400
- rated insulation voltage Ui (V)	440
- rated impulse withstand voltage Uimp (kV)	6
- conventional free air thermal current Ith (A)	63
- rated uninterrupted current Iu (A)	63
- rated frequency (Hz)	50/60
- utilization category	AC22B
Short-circuit characteristic	
- rated conditional short-circuit current (kA)	50
Co-ordination of short-circuit protective devices	
- kind of protective device	Fuses from 2 to 63A



LCIE – Laboratoire Central des Industries Electriques
 33, avenue du Général Leclerc – BP8
 FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 27/02/2017

Signature: **Jean-François BRUEL**
 Certification Officer