



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

Certificate No.: CE190304006163-A1

**Product** Fuse disconnector

**Applicant** MERSEN USA NEWBURYPORT-MALLC  
374 MERRIMAC ST NEWBURYPORT MA 01950, USA

**Type/Model** US\*CC\*

**Technical data** Uimp:8kV; Ui:1000V; Ith:30A; Ue:600VAC,600VDC;  
Ie:30A; Iq:100kA;Utilization Category: AC-20B,DC-20B;  
IP20; 1P,2P,3P,4P,3P+N(Switched Neutral Pole); 50/60Hz

This is to certify that, on the basis of the tests undertaken as per Report No. 00901  
CE2017CQC0304-009161-A1, the submitted sample(s) of the above item complies with:  
**EN 60947-3:2009 + A2:2015**

and fulfills testing requirements of the European Directive:  
**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only,  
and does not include the manufacturing process. Users shall affix the mark in accordance  
with the related legislation.

**Valid from:** Jun.18,2021

**Valid until:** Jun.18,2024

**President:**

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**  
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

**CE 0011527**