



Certificate of Compliance

Certificate: 70012102 (LR 12636)

Master Contract: 162842

Project: 70012102

Date Issued: March 9, 2015

Issued to: Mersen USA Newburyport-MA, LLC

374 Merrimac St
Newburyport, MA 01950-1998
USA
Attention: Marla Miller

*The products listed below are eligible to bear
the CSA Mark shown with adjacent indicator*



Ramana Tangirala

Issued by: Ramana Tangirala

PRODUCTS

CLASS 1422 30 - FUSES - Supplemental Fuses - Component Acceptance

Model "SC" Square Body Type Semi-Conductor Fuses:

- Cat No SC30AR followed by suffixes, 80 to 315A, 760V ac, 550V dc, Type "aR", IR 200kA at 760Vac and 100kA at 550V dc;
- Cat No SC31AR followed by suffixes, 315 to 500A, 760V ac, 600V dc, Type "aR", IR 200kA at 760Vac and 100kA at 600V dc;
- Cat No SC32AR followed by suffixes, 500 to 800A, 760V ac, 550V dc, Type "aR", IR 200kA at 760Vac and 100kA at 550V dc;
- Cat No SC33AR followed by suffixes, 800 to 1400A, 760V ac, 500V dc, Type "aR", IR 200kA at 760Vac and 100kA at 500V dc;
- Cat No SC33AR followed by suffixes, 1500 to 1800A, 660V ac, 450V dc, Type "aR", IR 200kA at 660Vac and 100kA at 450V dc;
- Cat No SC33AR followed by suffixes, 2000A, 605V ac, 450V dc, Type "aR", IR 200kA at 605Vac and 100kA at 450V dc;

Notes:



Supplement to Certificate of Compliance

Certificate: 70012102

Master Contract: 162842

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70012102	Mar 9, 2015	Covers original certification of Model #SC# Square Body Type Semi-Conductor Fuses, 760V ac max, 600V dc max, 80 to 2000A Fuses.