



# NIPPON KAIJI KYOKAI

## *Certificate of Type Test*

Certificate No.

TA16513M

MANUFACTURER: Mersen France SB SAS, France


PRODUCT: Low voltage HRC Fuse-links  
Cylindrical Fuse-links 14x51gG with or without striker

TYPE NO.: FR14GG69V, FR14GG50V

TYPE TEST NO.: 07T102

PARTICULARS: Rated voltage a.c. 690V, 500V  
Rated current 1~50A at a.c.690V without striker  
2~50A at a.c.500V with striker  
Rated breaking capacity 120kA at a.c.690V, 500V


STANDARD: IEC60269-1 Ed.4.1(2009), IEC60269-2 Ed.4.0(2010)

DOCUMENTATION: A127846 

THIS IS TO CERTIFY that the above mentioned product has been approved by the NIPPON KAIJI KYOKAI in accordance with the Society's type test requirements for electrical equipment and cables.

This certificate is valid until 26 September 2021.

Issued at Tokyo on 27 September 2016.



Y. Shibata  
General Manager  
Machinery Department

Note: The manufacturer, if desired, is requested to apply to the Society for renewal prior to the expiration date.